



Inspection Preparation Checklist Large Family Day Care



As an operator of a Large Family Day Care, your home will be inspected each year by the San Ramon Valley Fire District. This checklist will help you prepare for your inspection.

- Smoke Detectors must be present and functional in each sleeping area, outside each sleeping area and on each story.
- Smoke detectors should be tested monthly and batteries should be changed out at least once a year.
- Fire Extinguisher must be visible, readily accessible, with proof of service or purchase within the past 12 months.
- Manual Fire Alarm Device must be present and functional.
- Fire Drill Records must be available and show a fire drill has been conducted at least once every 6 months.
- Door between the garage and the house must self close and positive latch.
- Wall between garage and house must be in good condition and free of unsealed penetrations.
- Exiting doors must be in working order and exit paths free of obstructions. At least 2 exits are required.
- House address numbers must be clear and visible on outside of the home.



For More Information Contact
San Ramon Valley Fire District
925-838-6600
firedepartment.org