

Residential Care Facility for the Elderly

INSPECTION CHECKLIST

As an operator of a Residential Care Facility for the Elderly, your home will be inspected each year by the San Ramon Valley Fire District. This checklist will help you prepare for your inspection.

| Smoke Detectors must be present and functional in each sleeping area |
|--|
| outside each sleeping area and on each story. |
| Smoke detector should be tested monthly and batteries should be |
| changed out at least once a year. |

- ☐ Manual Pull Station required if smoke detectors are not interconnected.
- ☐ Fire Extinguisher must be visible, readily accessible, and serviced or purchased new within the past 12 months. Proof of service or purchase required.
- Door between the garage and the house must self close and positive latch.
- Wall between garage and house must be in good condition and free of unsealed penetrations.
- Exiting doors must be in working order and exit paths free of obstructions to provide a clear all weather surface to public walkway.
- Evacuation plan must be posted denoting all ambulatory, non-ambulatory and bedridden rooms with approved exit routes.
- House address numbers must be clear and visible on outside of the home.



For More Information Contact
San Ramon Valley Fire District
925-838-6600
firedepartment.org