



PLAN SUBMITTAL REQUIREMENTS

CLEAN AGENT SYSTEM

The San Ramon Valley Fire Protection District developed this Plan Submittal Guideline Standard to be used as a guide for submitting plans for fire extinguishing systems for clean agent systems.

REQUIRED DOCUMENT SUBMITTAL

1. Working plans shall be drawn to an indicated scale (not smaller than 1/8" = 1'), on sheets of uniform size (11" x 17" minimum). The following must be included in the plans. Stamp of Project Designer is required on all drawings
 - a. Jobsite address and parcel number
 - b. Business name
 - c. Name, address, and phone number of owner
 - d. Name, address, phone number, and stamp/signature of project designer/architect and or engineer
 - e. Editions of state and local governing codes
 - f. Point of compass
 - g. Symbol list
 - h. Location of all components of the system
2. Manufacturers' specification sheets for all the above. Use the same terminology on the plans as is in the design manual.

SUBMITTAL PROCESS

Submit plans electronically. Visit firedepartment.org/submitplans