



San Ramon Valley Fire Protection District
Community Risk Reduction Division
2401 Crow Canyon Road, Suite A, San Ramon, CA 94583
925.838.6600 www.firedepartment.org

PLAN SUBMITTAL REQUIREMENTS

GATES AND BARRICADES

The San Ramon Valley Fire Protection District developed this Plan Submittal Guideline Standard to be used as a guide for submitting plans for installation of gates and barricades across fire department access.

REQUIRED DOCUMENT SUBMITTAL

Working plans shall be drawn to an indicated scale (not smaller than 1/8" = 1') or contain necessary measurements. The following must be included in the plans:

1. **Cover Sheet Information:** job site address; business name; name, address and phone number of owner.
2. **Plot Plan:** scale or measurements; lot boundaries; north arrow; identification of all streets and right-of-ways adjacent to the site; existing or proposed driveways or roadways where gates are proposed including length, width and grade; proposed width of gate in both closed and open positions; location of emergency access key switch.

SUBMITTAL PROCESS

Submit plans electronically. Visit firedepartment.org/submitplans