



San Ramon Valley Fire Protection District
Community Risk Reduction Division
2401 Crow Canyon Road, Suite A, San Ramon, CA 94583
925.838.6600 www.firedepartment.org

PLAN SUBMITTAL REQUIREMENTS

LIQUIFIED PETROLEUM GAS

The San Ramon Valley Fire Protection District developed this Plan Submittal Guideline Standard to be used as a guide for submitting plans for installation of a Liquefied Petroleum Gas (LPG) tank.

REQUIRED DOCUMENT SUBMITTAL

Working plans shall be drawn to an indicated scale (not smaller than 1/8" = 1') or contain necessary measurements. The following must be included in the plans:

1. **Cover Sheet Information:** job site address; business name; name, address and phone number of owner.
2. **Plot Plan:** scale or measurements; lot dimensions; dimensions which indicate the distance from all existing buildings to adjacent property lines; north arrow; identification of all streets and right-of-ways adjacent to the site; location of easements and visible utilities on site; number, location, and capacities of proposed LPG container(s); manufacturer and serial number of container(s)

PLACE THE FOLLOWING NOTES VERBATIM ON THE PLAN

1. Installation shall be in accordance with California Fire Code and NFPA 58.
2. One set of SRVFPD approved plans shall always be retained at the job site.
3. Weeds grass brush trash and other combustible materials shall be kept not less than 10 feet from tanks or containers.
4. LP gas container subject to vehicle damage shall be protected by crash posts in accordance with CFC Section 312.
5. No smoking signs shall be posted.
6. Placarding of tanks in accordance with NFPA 704 is required.

SUBMITTAL PROCESS

Submit plans electronically. Visit firedepartment.org/submitplans