



San Ramon Valley Fire Protection District
Community Risk Reduction Division
2401 Crow Canyon Road, Suite A, San Ramon, CA 94583
925.838.6600 www.firedepartment.org

PLAN SUBMITTAL REQUIREMENTS

RURAL FIRE PROTECTION WATER SUPPLY

The San Ramon Valley Fire Protection District developed this Plan Submittal Guideline Standard to be used as a guide for submitting plans for Rural Fire Protection Water Supplies.

REQUIRED DOCUMENT SUBMITTAL

Working plans shall be drawn to an indicated scale (not smaller than 1/8" = 1'), on sheets of uniform size. The following must be included in the plans:

1. **Cover Sheet Information:** job site address; business name; name, address and phone number of owner; name, address, phone number and stamp/signature of project designer/architect and/or engineer; occupancy classification(s); type of construction; basic description of project; editions of State and local governing codes.
2. **Plot Plan:** scale; north arrow; building being protected by proposed water service; fire department access from public way to building being protected; tanks; piping; water supply source; pumping connections; detail showing all required tank connections; detail showing required venting and anti-vortex plates.
3. **Manufacturer Specification Sheets:** all tanks; piping; fittings.

PLACE THE FOLLOWING NOTES VERBATIM ON THE PLAN

1. One set of SRVFPD approved plans shall always be retained at the job site.
2. Inspection required before filling tanks.

SUBMITTAL PROCESS

Submit plans electronically. Visit firedepartment.org/submitplans